

IES INDOOR REPORT
PHOTOMETRIC FILENAME : L08TL09T-2W30HS-MA.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise

X=2H	Y=2H	13.9	15.7	14.3	16.0	16.3	6.7	8.5	7.1	8.8	9.1
	3H	17.2	18.8	17.6	19.2	19.5	7.4	9.0	7.7	9.3	9.7
	4H	18.9	20.5	19.3	20.8	21.2	7.9	9.5	8.3	9.8	10.2
	6H	21.2	22.7	21.6	23.0	23.4	10.9	12.3	11.3	12.7	13.1
	8H	22.4	23.9	22.9	24.2	24.6	12.6	14.0	13.0	14.4	14.8
	12H	23.8	25.1	24.2	25.5	25.9	14.1	15.4	14.5	15.8	16.2

UGR Viewed Endwise

4H	2H	14.2	15.8	14.6	16.1	16.5	8.7	10.3	9.1	10.7	11.0
	3H	17.9	19.3	18.3	19.6	20.0	10.2	11.5	10.6	11.9	12.3
	4H	19.8	21.0	20.2	21.4	21.9	10.9	12.2	11.3	12.6	13.0
	6H	22.4	23.5	22.9	24.0	24.4	12.9	14.0	13.4	14.5	14.9
	8H	23.8	24.9	24.3	25.3	25.8	14.3	15.4	14.8	15.8	16.3
	12H	25.4	26.4	25.9	26.9	27.3	16.3	17.2	16.7	17.7	18.2

8H	4H	20.2	21.3	20.6	21.7	22.2	13.1	14.1	13.5	14.6	15.0
	6H	23.1	24.0	23.6	24.5	25.0	15.4	16.3	15.9	16.8	17.2
	8H	24.7	25.5	25.2	26.0	26.5	16.8	17.6	17.2	18.1	18.6
	12H	26.5	27.3	27.0	27.7	28.3	18.2	19.0	18.7	19.5	20.0

12H	4H	20.3	21.3	20.8	21.7	22.2	14.0	15.0	14.5	15.4	15.9
	6H	23.3	24.1	23.8	24.6	25.1	16.6	17.4	17.1	17.9	18.4
	8H	25.0	25.7	25.5	26.2	26.8	18.0	18.8	18.5	19.3	19.8

Maximum UGR = 28.3